



THE DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA
MINISTRY OF PLANTATION AND COMMUNITY
INFRASTRUCTURE



RUBBER RESEARCH INSTITUTE OF SRI LANKA

RRISL/PRO/CAPITAL/AVIT/2026 (04)

11.05.2026

Registered Post

BID NOTICE

Purchase of PoE Surge Protectors

Bids are invited for quotations for Purchase of PoE Surge Protectors as per the specifications given in the attached sheet.

Sealed bids furnishing the information required **in the attached standard Bidding document (Annexure I) filling the all empty cages** should be send to the Director, Rubber Research Institute of Sri Lanka, Dartonfield, Agalawatta under registered cover or should be placed into the box available in the Account Department (Procurement unit), Dartonfield, Agalawatte. **Otherwise, they will be rejected.**

The envelope containing the Bid should bear the words **“Purchase of PoE Surge Protectors”** in its top left corner. Bids close at 10.30 am. On 25-05-2026 and they will be opened immediately after closing time on the same day at Dartonfield, Agalawatte. The decision of the Procurement Committee will be final and definite. Bidders or their authorized representatives will be permitted to be present for the event of opening of bids.

Chairman
Departmental Procurement Committee (Minor)
Rubber Research Institute of Sri Lanka
Dartonfield, Agalawatte

Annexure 1

Specifications of PoE Surge Protectors – 03 Nos.

Technical Specification

Feature	Description	Compliance (Yes/No/Detail).
PoE Surge Protectors – 03 Nos.		
Make	Should be internationally reputed brand. Please Specify	
Model	Please Specify	
Country of Origin	Please Specify	
Country of Manufacture	Please Specify	
LPZ	1 -> 3	
U_C	6V (58 V PoE)	
I_L	1 A	
$U_{P \text{ Line-Line}}$	< 40 V	
$U_{P \text{ Line-Earth}}$	< 900 V	
Impulse durability (8/20 μ s) (Line-Line)	C2: 0.3 kV / 0.15 kA	
Impulse durability (8/20 μ s) (Line-Earth)	C2: 3 kV / 1.5 kA	
I_{Total} (8/20 μ s)	5 kA	
Power over Ethernet	Yes	
Transmission class	CAT6 (1 Gbit/s)	
Other Features	High-quality RJ45 sockets	
	Earthing via DIN rail or connection cable	
	Support of Power over Ethernet + to 1 A	
	Tested transmission quality in networks up to 1 GB Cat6	
	Rapid installation through plug-in version	
	Incl. rail fastening set and earthing cable	
Certificates	Vendor should be registered under business names ordinance, partnership act or under company act of Sri Lanka. (The relevant letter should be attached)	
Vendor Experience	The vendor should have a minimum of three (03) years of recent experience in supplying Indirect Surge Protectors to government organizations and/or reputed private companies. (Proof should be attached).	
Manufacturer Experience	Principal manufacturer Should have minimum ten (10) year experience in manufacturing the similar products under the quoted brand name (Should be worldwide recognized brand).	
Warranty	The bidder should offer a <u>minimum of five (05) years of comprehensive warranty against manufacturing defects for the quoted surge protector model.</u>	

Validity Period of the Bid	
Total Price: Without VAT	
With VAT & Other Taxes	
Total price including all taxes (in figures)	
(in words)	

Name of the Authorized Officer

Signature of the Authorized Officer

Name of the Company & Address

.....

VAT Registration No.

Address

.....

Telephone Nos.

Rubber Stamp

Date: