



THE DEMOCRATIC SOCIALIST REPUBLIC OF SRI LANKA
MINISTRY OF PLANTATION AND COMMUNITY
INFRASTRUCTURE



RUBBER RESEARCH INSTITUTE OF SRI LANKA

RRISL/PRO/CAPITAL/AVIT/2026 (03)

11.05.2026

Registered Post

BID NOTICE

Supply of Indirect Surge Protector for Power Panel – 02 Nos

Bids are invited for quotations for Supply of Indirect Surge Protector for Power as per the specifications given in the attached sheet.

Sealed bids furnishing the information required **in the attached standard Bidding document (Annexure I) filling the all empty cages** should be send to the Director, Rubber Research Institute of Sri Lanka, Dartonfield, Agalawatta under registered cover or should be placed into the box available in the Account Department (Procurement unit), Dartonfield, Agalawatte. **Otherwise, they will be rejected.**

The envelope containing the Bid should bear the words **“Supply of Indirect Surge Protector for Power Panel – 02 Nos”** in its top left corner. Bids close at 10.30 am. On 25-05-2026 and they will be opened immediately after closing time on the same day at Dartonfield, Agalawatte. The decision of the Procurement Committee will be final and definite. Bidders or their authorized representatives will be permitted to be present for the event of opening of bids.

**Chairman
Departmental Procurement Committee (Minor)
Rubber Research Institute of Sri Lanka
Dartonfield, Agalawatte**

Technical Specifications of **Supply of Indirect Surge Protector for Power Panel – 02 Nos.**

	Description / Minimum Requirement	Compliance (Yes / No)	Remarks
Make	Please Specify (Should be international reputed brand)		
Model	Please Specify		
Country of Origin	Please Specify		
Country of Manufacturer	Please Specify		
Technical Specifications	Nominal voltage=230V Protection level = Class 1+2 3 Phase-4 Wire Total discharge current $I_{total} (10/350) = 25kA$ Nominal discharge current $(8/20) I_n = 30kA$ Impulse discharge current $(10/350) I_{imp} = 7k$ Arrestor surge current $(8/20) [I_{total}] = 120kA$ Maximum discharge current $(8/20 \mu s) = 50kA$ Protection rating =IP20, with visual function display(analog). (Should be attached Technical Data Sheet of the quoted surge protector model)		
Standards	The quoted surge protector model should comply with relevant international standards such as IEC 61643-11.		
Certificates	Vendor should be registered under business names ordinance, partnership act or under company act of Sri Lanka. (The relevant letter should be attached)		
Vendor Experience	The vendor should have a minimum of three (03) years of recent experience in supplying Indirect Surge Protectors to government organizations and/or reputed private companies. (Proof should be attached).		
Manufacturer Experience	Principal manufacturer Should have minimum ten (10) year experience in manufacturing the similar products under the quoted brand name (Should be worldwide recognized brand).		
Warranty	The bidder should offer a <u>minimum of five (05) years of comprehensive warranty against manufacturing defects for the quoted surge protector model.</u>		

	Validity Period of the Bid	
Total Price:	Without VAT	
	With VAT & Other Taxes	
	Total price including all taxes (in figures)	
	(in words)	

Name of the Authorized Officer

Signature of the Authorized Officer

Name of the Company & Address

.....

VAT Registration No.

Address

.....

Telephone Nos.

Rubber Stamp

Date: